



AIR EMISSION INVENTORY SHEET

Version 1

Name of Company/Production Unit: PRETTY SWEATERS LTD.	
Updated on:	Date: 04/04/2017
Responsible Person	Name: Md. Amirul Islam
	Designation: Manager (Maintenance)

S.I.No	EMISSION POINT	NAME OF POLLUTANT	SOURCE/ EQUIPMENT	EMISSION AMOUNT (AND UNITS)	LEGAL EMISSION LIMIT(IF ANY)	MONITORING FREQUENCY	ANY CONTROL DEVICES INSTALLED	DATE OF LAST AIR EMISSION TEST	EMERGENCY CONTACT PERSON(NAME, DESIGNATION & CONTACT NO.)	CHECKED BY(NAME & DESIGNATION)	CHECKED ON(DATE - FORMAT DD/MM/YYYY)	REMARKS
1	Stack #1	1.Particulate. 2.Oxides of Nitrogen	GAS Generator (1.5 MW)		1. 350 mg/Nm3 2. 30 PPM	Annual	No	N/A	Md,Arif Hasan Jony Desg: Asst.Manager (Compliance)	Engr. Amirul Islam Desg: Manager (Maintenance)	23/04/2017	
2	Stack #2	1.Particulate. 2.Oxides of Nitrogen	GAS Generator (1.5 MW)		1. 350 mg/Nm3 2. 30 PPM	Annual	No	N/A	Md,Arif Hasan Jony Desg: Asst.Manager (Compliance)	Engr. Amirul Islam Desg: Manager (Maintenance)	23/04/2017	
3	Stack #3	1.Particulate. 2.Oxides of Nitrogen	Diesel Generator (1000KW)		1. 350 mg/Nm3 2. 30 PPM	Annual	NO	N/A	Md,Arif Hasan Jony Desg: Asst.Manager (Compliance)	Engr. Amirul Islam Desg: Manager (Maintenance)	23/04/2017	
4	Stack #4	1.Particulate. 2.Oxides of Nitrogen	Diesel Generator (400KW)		1. 350 mg/Nm3 2. 30 PPM	Annual	No	N/A	Md,Arif Hasan Jony Desg: Asst.Manager (Compliance)	Engr. Amirul Islam Desg: Manager (Maintenance)	23/04/2017	
5	Stack #5	1. Soot & Particulate. 2.Oxides of Nitrogen	Gas Boiler (3.0 Ton)		1. 100 mg/Nm3 2. 150 mg/Nm3	Annual	No	N/A	Md,Arif Hasan Jony Desg: Asst.Manager (Compliance)	Engr. Amirul Islam Desg: Manager (Maintenance)	23/04/2017	
6	Stack #6	1. Particulate. 2.Oxides of Nitrogen	Gas Boiler (6.0 Ton)		1. 100 mg/Nm3 2. 150 mg/Nm3	Annual	No	N/A	Md,Arif Hasan Jony Desg: Asst.Manager (Compliance)	Engr. Amirul Islam Desg: Manager (Maintenance)	23/04/2017	